

EU DECLARATION OF CONFORMITY

No. 1A-EU-01/23-02

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
Havlíčková 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Electroinstallation boxes for mounting under plaster and accessories**

manufacturer: **KOPOS KOLÍN a.s., Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Electroinstallation boxes are made of materiál: PVC
Temperature resistance of the boxes: -5 °C to + 60 °C.
Passing the glow-wire test at temperature: 850°C
The needle flame test was conducted in accordance with: ČSN EN 60695-11-5 with satisfactory result.

Halogen free boxes are made of material: PC/ABS
Temperature resistance of the boxes halogen free: -5 °C to + 60 °C.
Passing the glow-wire test at temperature 850°C.
The needle flame test was conducted in accordance with: ČSN EN 60695-11-5 with satisfactory result.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification/tested product
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21+A11:21 including amendments ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 220851-01/01 of 12.08.2022 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	KU 68-45- grey, KU 68-45-black, V 68- white, KPR 68-70-grey, KO97/5-grey, KO 97/V-white, KO 100-grey, KO 100V-white, KT 250-grey, KT 250V- white.
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN IEC 60670-1 ed. 2:21+A11:21 including amendments ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 220851-01/02 of 12.08.2022 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	KU 68-45/HF, V 68 HF, KPR 68-70/HF, KO 97 V/1 HF, KO 97/5 HF.
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Test Report No. 913245-01/01 of 30.1.2020	KU 68 HF, KP 68/2 HF, V 68 HF.

	Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 603370-01/01 of 9.12.2019 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	X
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 911221-01/01 of 12.7.2019 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Testing of ESC branded products – KO 100
			Test Report No. 801482-01/01 of 26.4.2018 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	Testing of ESC branded products – KP 68
X	X	ČSN EN 60670-1, ČSN EN IEC 60670-1 ed.2	Internal test Report No. 011/2022 of 16.5.2022	KU 68-45
X	X	ČSN EN 60670-1, ČSN EN IEC 60670-1 ed.2	Internal test Report No. 012/2022 of 16.5.2022	KU 68-45/HF
X	X	ČSN EN 60670-1, ČSN EN IEC 60670-1 ed.2	Internal test Report No. 013/2022 of 16.5.2022	KPR 68-70
X	X	ČSN EN 60670-1, ČSN EN IEC 60670-1 ed.2	Internal test Report No. 014/2022 of 16.5.2022	KPR 68-70/HF
Regulation 1907/2006 - REACH	X	X	X	Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.


Signed on behalf of KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 28.02.2023



Ing. Jana Dejmková
quality director

KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz


Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-01/23-02 Wiring boxes for mouting under plaster

Electroinstallation boxes	Rating	Instrument box	Rating
Type		Type	
KU 68-45	400 V	KPR 68-70	400 V
KU 68-45/V	400 V	KPR 68	400 V
KU 68	400 V	KPR 68/71	400 V
KU 68/1	400 V, 16 A	KPM 64	400 V
KU 68-1901	400 V, 16 A	KOM 97	400 V
KU 68-1902	400 V, 16 A		
KU 68-1903	400 V, 16 A	Covers	
KU 68/71 - 1	400 V, 16 A	KO 68	
KU 68/71 - 2	400 V, 16 A	V 68	
KU 68/71 - 3	400 V, 16 A	V 68 S	
KP 67/1	400 V	V 68 V HB	
KP 67/2	400 V	KO 97 V	
KP 67/3	400 V	KO 97 V/1	
KJ	400 V, 16 A	KT 250V	
KP 68	400 V	KO 100V	
KP 68/2	500 V	KO 125V	
KP 21	500 V	V 100 E	
KP 67x67	500 V	V 125 E	
KP 64/2	400 V, 16 A	V 125/1	
KP 64/3	400 V, 16 A	ZV 68	
KP 64/4	400 V, 16 A	ZV 97	
KP 64/5	400 V, 16 A	V 35	
KP 64/LE	400 V, 16 A	V 45	
KO 97	500 V		
KR 97	500 V	Frame	
KP 45	400V, 16A	NR 68/6	
KO 97/5	500 V	NR 68/10	
KR 97/5	500 V	NR 5x5	
KR 35	400 V, 16 A	Terminal	
KO 100	500 V	S - 66	
KO 100 E	500 V	S - 96	
KO 125	500 V	SP - 96	
KO 125 E	500 V		
KO 125/1	500 V	Distance bar	
KR 100	500 V	DR 18	
KR 100/1	500 V		
KR 100/2	500 V	Distance bar	
KR 125	500 V	DR 42	
KR 125/1	500 V		
KR 125/2	500 V	Blind cover	
KUH 1	400V, 16A	ZV 68/D	
		ZV 68	
B 17	230V, IP 20	(materiál PE)	
		ZV 97	
KT 250	500V	(materiál PE)	
KT 250/1	500V		
		Thorn extension	
KT 250x110	500V, IP 30		
KT 250/2	500V	TN 68	
		TN 97	

Wiring boxes for mouting under plaster -halogen free (HF)

Boxes	Rating	Covers
Type		
KU 68-45/HF	400 V	KO 68 HF
KU 68-45/V HF	400 V	V 68 HF
KU 68 HF	400 V, 16 A	V 68 S HF
KU 68/1 HF	400 V, 16 A	V 68 S HB HF
KU 68-1901 HF	400 V, 16 A	KO 97 V HF
KU 68-1902 HF	400 V, 16 A	KO 97 V/1 HF
KU 68-1903 HF	400 V, 16 A	KT 250 V HF
KU 68/71 - 1 HF	400 V, 16 A	KO 100 V HF
KU 68/71 - 2 HF	400 V, 16 A	KO 125 V HF
KU 68/71 - 3 HF	400 V, 16 A	V 100 E HF
KP 68 HF	400 V	V 125 E HF
KP 67/1 HF	400 V	V 125/1 HF
KP 67/2 HF	400 V	ZV 68 HF
KP 67/3 HF	400 V	ZV 97 HF
KJ HF	400 V, 16 A	V 35 HF
KP 68/2 HF	400 V	V 45 HF
KP 21 HF	500 V	V 68
KP 67x67 HF	500 V	KO 68V
KP 64/LE HF	400 V, 16A	
KP 64/2 HF	400 V, 16 A	Terminal
KP 64/3 HF	400 V, 16 A	S - 66
KP 64/4 HF	400 V, 16 A	S-96
KP 64/5 HF	400 V, 16 A	SP -96
KO 97 HF	500 V	
KR 97 HF	500 V	Distance bar
KO 97/5 HF	500 V	DR 18 HF
KR 97/5 HF	500 V	
KUH 1	400V, 16A	Distance bar
B 17 HF	230 V, IP 20	DR 42 HF
KT 250 HF	500V	
KT 250/1 HF	500V	Frame
KT 250x110 HF	500V, IP 30	NR 68/6 HF
KT 250/2 HF	500V	NR 68/10 HF
		NR 5x5
Instrument box		
Typ		
KPR 68-70/HF	400 V, 16 A	
KPR 68 HF	400 V, 16 A	
KPR 68/71 HF	400 V, 16 A	
KPM 64 HF	400 V, 16 A	
KOM 97 HF	400 V, 16 A	



KOPOS KOLÍN a.s. 
 Havlíčkova 432, 280 02 Kolín
 IČ: 616 72 971 DIČ: CZ61672971
 tel: 321 730 111 www.kopos.cz

